

Thumbs Up Checklist

Name of Location:	Date:Time:
Address:	
Code: Y YES N/A N/A-Not Applicable NO	Floors and Aisles
Parking Lot and Sidewalks	wide enough for walkers, wheelchairs and scooters
free of large cracks, holes, uneven surfaces and/or dangers clearly identified with contrast paint, a sign or pylon.	access to exits clear well lit
well lit	Stairs (indoor / outdoor) □
disabled spaces are clear, accessible and have a vertical sign.	railings firmly attached both sides extends beyond top
Entrances & Exits	well lit & bottom degrees marked with a contrasting colour,
Must have one of these:	texture or lights
self-opening doors	in good condition elevator
disabled push button doorbell	
	Public Washrooms
Entrances have: clear opening of no less than 81 cm	wheelchair accessible cubicle 1.5m x 1.5m
even surfaces	cubicle door swings outward well lit
a ramp 1.5 m wide if stairs present	equipped with grab bars
handrails for ramps and steps ideally on both sides	have a family washroom
well lit	
doors that allow customers to see	Shelves, Racks and Displays \square
someone coming in or out doors that can be opened easily (door	secure & do not move or tip
knobs, weight of door)	allow you to move around them easily
doors that open and close at a safe speed	items within reach or assistance available
glass doors marked at eye level phone	_
seating in the entrance/exit	Carts & Baskets □
	available maintained
**Adapted from: "Stepping Out Safely;" Trauma Prevention	easy to manage powershopper provided
Council – Central West	Visually Impaired
*** Disclaimer:	Signage:
This information is being provided as a community service only and does not imply that this location is 100% barrier free or safe.	large print
The Thumbs Up program and all partner agencies are not responsible for any claims made against this location.	braille
1	washrooms elevator exit
	Customer Service
	courteous customer service
General Comments	Will receive Thumbs Un deed
General Comments	Will receive Thumbs Up decal Decal given □
	Decui given

Revised April 2011

Checked by: